

Docket
14-00000000

Monthly Update
31-Jul-15

Wastewater Location	Date Complaint /Repair Needed	Complaint	Date added to Report	Explain Repairs/Improvements Planned	Explain Repairs/Improvements In Progress	Money Expended	Manner to be funded	Estimated Cost	Estimated Complete Date	Date Completed	Final Costs
Cedar Hill			9/29/2014	see Docket 14-00136							
Maple Green			9/29/2014	see Docket 14-00136							
Summit View				see Docket 14-00136							
Smokey Village				see Docket 14-00136							
Star Crest	11/17/2014	E Coli limits not met	11/30/2014	Fencing Required	Fence Installed, Additional Drip needed			1200	8/31/2015	8/31/2015	1400
Star Crest II	11/17/2014	E Coli limits not met	11/30/2014	Fencing Required	Fence Installed			1800	2/21/2015	2/20/2015	1600
Townsend Town Sq.	11/17/2014	E Coli limits not met	11/30/2014	Fencing Required	Fence Installed			15000	3/1/2015	1/15/2015	14277
Legacy Mtn East	10/1/2014	E Coli limits not met	10/30/2014	Fencing Required	Fence Installed					10/30/2014	1770