



STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
DIVISION OF WATER RESOURCES

William R. Snodgrass - Tennessee Tower  
312 Rosa L. Parks Avenue, 11th Floor  
Nashville, Tennessee 37243-1102

14-00136

March 3, 2017

Mr. Charles R. Hyatt, CEO  
Adenus Group, LLC  
e-copy: charles.hyatt@adenus.com  
849 Aviation Parkway  
Smyrna, TN 37167

Subject: **State Operating Permit No. SOP-06035**  
**Tennessee Wastewater Systems, Inc. d/b/a Summit View Resort**  
**Summit View Resort**  
**Sevierville, Sevier County, Tennessee**

Dear Mr. Hyatt:

The Division of Water Resources (the division) has received your application for the above referenced project on 13-FEB-17. We have reviewed the application for completeness in accordance with TDEC rule 1200-4-5-.05 (2) and find the application to be incomplete. As you are aware additional information related to the recent engineering plan submittal was requested in a letter dated February 16, 2017 from Brad Harris. The processing of this application has been suspended until the information requested in the letter is received. This information includes:

A new survey showing the location all existing systems and constitute record drawings for the site.

Provide deed, easements or other agreements that authorize TWSI to use specified property for the treatment plant and land application areas currently being utilized and matching the detailed survey.

Proposed drip zones and expansion construction shall be shown on separate sheets with 5 foot or more accurate contour spacing and property boundaries accurately depicted. Drip zones shall be shown super-imposed on approved soil surveys with pit locations shown on the proposed new drip area.

Proposed construction shall be indicated with existing features screened back as in conventionally produced site drawings.

The currently proposed or modified construction plans will be reconsidered upon clarification of the accurate boundaries, existing site plan and land application areas available to TWSI.

Modifications in the construction approval and the State Operating Permit based on the new plans.

You should be aware that in accordance with TDEC Rule 1200-4-5-.05 (2), your receipt of this notice does not preclude the division from later requesting additional material that subsequent to the notice of completeness is determined to be necessary for permit processing.

If you have questions, please contact the Knoxville Environmental Field Office at 1-888-891-TDEC; or, at this office, please contact Mr. Allen Rather at (615) 532-5819 or by E-mail at *Allen.Rather@tn.gov*.

Sincerely,

A handwritten signature in black ink, appearing to read "Brad Harris", with a stylized flourish at the end.

Brad Harris, P.E.  
Manager, Land Based Systems

Enclosure

cc: Permit Section File  
Knoxville Environmental Field Office  
Mr. David K. Beverly, Consulting Engineer, , *copperridge303@bellsouth.net*  
Mr. Jeramy Stewart, Operator, TWSI, *jeramy.stewart@adenus.com*  
Ms. Michelle Ramsey, Utilities Division, Tennessee Regulatory Authority, *michelle.ramsey@tn.gov*  
Mr. Kevin Dean, Attorney, Fraantz, McConnell & Seymour LLP, *kdean@fmsllp.com*  
Ms. Patsy Fulton, Utility Rate Specialist, Tennessee Regulatory Authority, *Patsy.Fulton@tn.gov*