



Tennessee Wastewater Systems, Inc.
Docket 15-00025
January 2018 Report Overview

Systems subject to Notice of Violations and other Corrective Orders:

Starr Crest II (NOV) – HOA and owners have approved of the agreement with Adenus to expand the treatment system. Agreement has been executed and construction schedule is being set with commencement expected to begin within the next few weeks.

Smoky Village (NOV) – Docket 16-00096 – Settlement Agreement with CPAD has been filed in the docket.

Summit View – Docket 14-00136 – TDEC has reinstated the construction plans for the site.

Cedar Hill – Docket 16-00096 – Settlement Agreement with CPAD has been filed in the docket.

Maple Green (NOV) – Docket 16-00096 – Settlement Agreement with CPAD has been filed in the docket.

River Road* (NOV) – TWSI is awaiting a signed easement for the land occupied by the sewer system. This is the final requirement TDEC had for the site.

Hidden Springs Resort (NOV) – Soils work is being conducted onsite to determine suitable soils for the necessary drip field expansion. Plans to overhaul the treatment facility continue to be developed.

* River Road is not included in the KPI Report because there is no discharge from the facility and is not monitored.

Jeff Ridsen

From: HAWKMS Agent <agent@hawkms.com>
Sent: Monday, January 1, 2018 7:50 AM
To: Charles Hyatt; Brian Carter
Cc: Jeff Ridsen; Bob Pickney; Matt Pickney
Subject: TRA KPI Compliance Report for 1/1/2018 7:50:02 AM

TPUC Flow KPI Report for 12/31/2017

Tracy Nichols	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Cedar Hill DCP	75000	29500	0	0.00	9710.33	
Maple Green DCP	74000	48029	51710	1.08	31605.67	

Jeremy Stewart	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Hidden Springs RSF	30750	19600	25294	1.29	18969.57	
Starr Crest II BC	28000	23450	35775	1.53	25945.40	
Summit View RSF	8000	5775	7990	1.38	4123.45	

Brandon Dotson	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Smoky Village RSF	5600	5075	2143	0.42	2007.93	

Jeff Ridsen

From: Bob Pickney
Sent: Thursday, December 21, 2017 10:23 AM
To: George Garden (George.Garden@tn.gov); Brad Harris
Cc: Jeff Ridsen; Marshall Fall
Subject: Hidden Springs

George/Brad,

Marshall and I are working with Jeramy Stewart to change the way the Fast units are dosed with effluent – we have discussed this site with BioMicrobics technicians – were are changing to a constant flow of influent versus a dosed flow – hopefully this will reduce the odor by keeping the aeration potion aerobic – we will be monitoring to evaluate the system –

Thanks,

Bob Pickney