



**Tennessee Wastewater Systems, Inc.
Docket 15-00025
June 2019 Report Overview**

Systems subject to Notice of Violations and other Corrective Orders:

Smoky Village (NOV) – Docket 16-00096 – Drip field is being installed. It is anticipated that the installation will be complete mid-Summer.

Summit View – Docket 14-00136 – TDEC has reinstated the construction plans for the site.

Maple Green (NOV) – Docket 16-00096 – Work has begun at the site. It is anticipated, that work will be complete within the next 4-6 weeks.

River Road* (NOV) – TWSI is awaiting a signed easement for the land occupied by the sewer system. This is the final requirement TDEC had for resolution of the NOV.

Hidden Springs Resort (Commissioner's Order) – HOA is drafting the easement to grant TWSI permanent use of the land necessary to expand the wastewater system. Plans have been submitted to TDEC for approval.

* River Road is not included in the KPI Report because there is no discharge from the facility and is not monitored.

Jeff Riden

From: HAWKMS Agent <agent@hawkms.com>
Sent: Saturday, June 1, 2019 7:53 AM
To: Jeff Riden; Matthew Nicks
Cc: Bob Pickney
Subject: TPUC KPI Compliance Report for 6/1/2019 7:50:01 AM

TPUC Flow KPI Report for 5/31/2019

Tracy Nichols	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Maple Green DCP	74000	29400	0	0.00	0.00	

Jeremy Stewart	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Hidden Springs RSF	30750	19425	7019	0.36	5240.27	
Summit View RSF	8000	5775	4857	0.84	4114.13	

Brandon Dotson	Permitted	Expected	Actual	% of Expected	AvgFlow	% o
Smoky Village RSF	5600	4725	1668	0.35	1367.60	